

From: Patricia Terceiro
Sent: 07 June 2019 10:05
To: development.control
Subject: FW: Emailing 30823 R1.pdf

Hi TS,

Please register the email below as an environmental health response to application 18/0413.

Thank you,
Patricia

From: James Robinson
Sent: 06 November 2018 10:36
To: Patricia Terceiro
Subject: RE: Emailing 30823 R1.pdf

Hi Patricia

The noise impact assessment demonstrates that noise levels from the plant extract is likely to be 5dB below the existing background levels when measured 1 metre in front of the nearest residential window. As such the impact is rated as low and I have no objections to the application. However the assessment uses typical plant noise and not that specific to the site. In these circumstances, and to ensure that noise breakout from plant within the building does not adversely affect residential above a condition would be appropriate. Such a condition would be;

Prior to commencement of work details of extraction plant serving the proposed to be submitted to and agreed in writing by the LPA.

Reason: To demonstrate that plant noise does not exceed 35dBa at 1 metre in front of nearest residential window, and that the power rating of any proposed installed plant does not exceed 65dBA when measured at 1 metre.

Kindest Regards

James

From: Patricia Terceiro
Sent: 30 October 2018 14:55
To: James Robinson
Subject: FW: Emailing 30823 R1.pdf

Hi James,

I'm not sure if I actually ever re-consulted you on 18/0413 (attached noise report). In any instance, can I please have your comments?

Thanks,
Patricia

From: Judith Charles [<mailto:judith@m3architecturaldesign.co.uk>]
Sent: 17 September 2018 15:37
To: Patricia Terceiro
Subject: Emailing 30823 R1.pdf

Dear Patricia

Please find attached the sound assessment for Everest food store.

Many thanks
Judith